

Owner's Manual — Phoenix Guardian HEPA System

Installation, Operation & Service Instructions

Read and Save These Instructions

The Phoenix Guardian HEPA System remains the first portable air scrubbing device designed exclusively for the restoration industry. The Guardian can perform several critical air quality remediation functions simultaneously.

The Guardian HEPA System captures virtually all removable airborne particles. The optional 4-stage absorption filter contains a blend of activated carbon and potassium permanganate to remove airborne odors and chemicals.

The true 1400 cfm capacity of the Phoenix Guardian HEPA System will clean one air change of a 12 x 14 foot room in less than a minute. In order to be effective, an air scrubber should be able to perform a minimum of four air changes per hour. Therefore, a single Guardian can be expected to control up to 21,000 cubic feet.

The Guardian's high airflow and multiple ducting options allow for the combination of negative or positive air flow control of an area and containment air scrubbing at the same time. This provides the unique ability to continually filter the indoor air and depressurize the damaged site to prevent the spread of contamination simultaneously.

The Guardian's intake will accept either 18" flex-duct or 12" flex-duct with the included adapter, to pressurize areas for protection from contamination or to draw contaminated air from areas that are difficult to access or too small to accommodate an air scrubbing device.

Every Guardian HEPA System comes with one 14" lay-flat duct ring, for 100% negative air operation, and two 10" lay-flat duct rings for a combination of negative air, air scrubbing or positive airflow.



Phoenix Guardian HEPA System
PN 4024848

The Phoenix Guardian HEPA System

- 2-Speed operation (1400-900 CFM)
- Multiple ducting options
- Built-in manometer
- Only 12 amps
- Stainless steel cabinet
- Optional fourth stage carbon filter
- Wheeled cart design

Table of Contents

Introduction	1
1. Specifications	2
2. Operation	2
2.1 Transporting the Phoenix Guardian.....	2
2.2 Location	2
2.3 Electrical Requirements	2
2.4 Limiting Amp Draw.....	3
2.5 Air Ducting.....	3
2.5A Inlet Ducting	3
2.5B Outlet Ducting.....	4
2.6 Negative Air Ducting	5
2.7 Power/Speed Switch	5
2.8 Hour Meter	5
3. Maintenance	5
3.1 Air Filters.....	5
3.1B Carbon/Potassium Permanganate Filter.....	6
3.2 Checking Airflow	6
4. Service	7
4.1 Warranty	7
4.2 Blower Motor Replacement	7
5. Wiring Diagram	7
6. Service Parts List	8
7. Warranty.....	9

Serial No. _____

Purchase Date _____

Dealer's Name _____

Read the operation and maintenance instructions carefully before using this unit. Proper adherence to these instructions is essential to obtain maximum benefit from your Phoenix Guardian HEPA System dehumidifier.

1 Specifications

Part No.	4024848
Power	12 amps, 110-120 VAC, Grounded
Blower	2-Speed High: 1400 CFM* w/o external duct Low: 900 CFM* w/o external duct

Duct Connections:

Inlet: 18" diameter: 18" flex duct can be connected directly to the top; 12" dia. adapter for flex duct

Outlet: 10.5" square: (3) Rectangular wire-form collars for lay-flat plastic ducting; (1) for 14" & (2) for 10"; 12" diameter adapter for flex duct

Filters:	24" x 24"
1-stage	1" Spun Polyester
2-stage	2" Pleated Media
3-stage	12" V-bank HEPA
(optional) 4-stage	2" Carbon and Potassium Permanganate

Warranty One Year, 100% Parts and Labor

Dimensions

	Machine	Shipping
Width	25"	29"
Height	39"	45"
Depth	25"	28"
Weight	121 Lbs	155 Lbs

2 Operation

2.1 Transporting the Phoenix

The Phoenix Guardian should be upright when transported by vehicle. It may be tipped on to its back for loading and moving by hand.

2.2 Location

Note the following precautions when locating the Phoenix Guardian:

- It is designed to be used **INDOORS ONLY**.
- If used in a wet area, plug it into a **GROUND FAULT INTERRUPTER**.
- **DO NOT** use the Phoenix Guardian HEPA System as a bench or table.
- It must always be used in the upright position.
- The air inlet on top & the front outlet should be at least 1 foot from walls and other obstructions to airflow.

2.3 Electrical Requirements

The Phoenix Guardian can be plugged into a grounded 15 Amp circuit. It draws 12 Amps or less with clean filters and no ducting (if less amperage is available, see Section 2.4).

Due to the high percentage of a 15 Amp circuit's capacity that the unit uses, the circuit should be dedicated to running the Phoenix Guardian HEPA System only. Amp draw decreases as filters get dirty and ducting is added.

CAUTION

CAUTION: The unit must always be operated with all three filters and the top in place. Operating it with one or more filters missing, the top off, and/or inferior filters will cause the amperage to increase and the motor to overload.

If an extension cord is required, it must have a minimum of 12 gauge conductors if 25 feet long or less and 10 gauge conductors if greater than 25 feet long.

2.4 Limiting Amp Draw

In certain conditions, allowing the unit to draw its normal 10 to 12 Amps may be undesirable. Limited amperage available may be needed to run other equipment. In such conditions, amp draw can be reduced by restricting the airflow at the inlet with the unit running on either speed.



Figure 1



Figure 2



Figure 3

The 18" diameter inlet grid can be restricted by partially covering it with anything convenient and stiff enough to maintain its shape (cardboard, sheet metal, plywood). The negative air pressure at the inlet will help hold the restrictor in place.

2.5 Air Ducting

2.5A Inlet Ducting

Occasionally the area to be filtered is difficult to access and/or the unit cannot be located in the area. In such cases, the air can be ducted to the unit's inlet.

A round 18" diameter flex duct can be attached to the unit inlet on top. It connects by hooking the spiral wire of the flex duct under the four tabs inside the perimeter of the inlet opening; see figures 1, 2 and 3.

Flexible 18" ducting is available from Therma-Stor.

An adapter is included that allows 12" flexible ducting to be connected to the inlet. It is stored on the unit's side. Flex duct is pushed through the adapter center with the adapter hooking tabs facing away from duct; (see figure 4).



Figure 4




Figure 5



Figure 6



Figure 7

The spiral wire passes from one side of the adapter to the other via the notch on the hole edge; (see figure 5).

The adapter and duct are positioned on the unit top with the four tabs placed into the slots. The adapter is then twisted counterclockwise to lock it in place; see figures 6 and 7.



Figure 8



Figure 9



Figure 10




Figure 11

2.5B Outlet Ducting

Three rectangular wire-form collars are supplied that will allow round lay-flat plastic ducts to be attached to the Phoenix Guardian outlet. The two small collars are made for 10" lay-flat duct; the large one is for 14". Lay-flat plastic ducting is available from Therma-Stor.

To attach ducting to a collar, remove the collar from the unit by loosening the two wing knobs above the collars and sliding the collar out. Put the plastic duct end through the collar center from the front. Fold the duct end outward so that it overlaps the outside of the collar by several inches.

The same adapter that allows 12" flexible ducting to be connected to the inlet can be used to connect 12" flexible duct to the outlet. It is stored on the unit's side. Flex duct is pushed through the adapter center with the adapter hooking tabs facing toward the duct, (see figure 8 and 5).

The four thumb screws that hold the two outlet collar guides must be removed; set the guides aside and reinstall the thumb screws, (see figures 9 and 10).

The adapter and duct are positioned on the unit front so the four slots in the adapter fit over the thumb screws. Rotate the adapter so the thumb screws are at the end of the slots and tighten the screws; see figure 11.

2.6 Negative Air Ducting

The Phoenix Guardian can be used to filter and exhaust air from a space. By exhausting to outside the space, the space will be under a slight negative pressure. This will help prevent airborne particles from leaving the space, since the negative pressure will draw air in through openings in the space's exterior.

The quantity of air exhausted depends on how the unit is ducted and which speed is used. One or two ducts can be directed outside. If all the filtered air is ducted outside, this would result in up to 1300 CFM being exhausted on high speed and an equal amount of fresh air being drawn in.

CAUTION

CAUTION: Exhausting too much air from a space with open combustion devices (e.g. furnace, fireplace or water heater) can cause those devices to backdraft. This can contaminate the space with potentially fatal gases. In such cases, the Phoenix Guardian must be used in one of the following three ways: (A) as a filtering unit only. Exhausting no air from the space and thus causing no negative pressure or backdrafting. (B) Exhausting a very limited amount of air which does not cause backdrafting. In case B, the open combustion devices must be thoroughly checked to guarantee that they do not backdraft while the Phoenix Guardian is running. (C) direct one or more outlet ducts from the Guardian to the room with the open combustion device(s). This will positively pressurize the room, thus preventing backdrafting. As in case B, those combustion devices must be checked after the Guardian is running to guarantee that they are not backdrafting.

One duct can be directed outside, exhausting a portion of the filtered air. The rest of the filtered air can be recirculated inside the space with or without outlet ducting. Varying the collars' position in the guides at the outlet can control the quantity of air exhausted. To determine precisely the amount exhausted, an airflow meter is required.

2.7 Power/Speed Switch

The power/speed switch is located on the unit side. When turned on to high or low speed, it powers the blower and hour meter.

Occasionally the blower may not start on low speed. If this occurs, start the unit on high speed, then switch it to low speed.

CAUTION

CAUTION: Do not remove the top to access the filters with the unit on. Removing the top and filters while running can: (A) damage the blower motor by causing it to overload, (B) expose potentially fatal high voltage electrical parts, (C) expose the dangerous rotating blower impeller.

2.8 Hour Meter

A digital hour meter is located near the power switch on the unit side. It measures the cumulative time that the unit is turned on to tenths of an hour. It stores its total when the unit is unplugged. The previous total will be displayed when the unit is on or off. It resets to zero after 99,999.9 hours of operation.

3 Maintenance

3.1 Air Filters

The standard Phoenix Guardian is equipped with three filters that progressively filter out smaller particles. An optional activated carbon/potassium permanganate filter can be used, giving a fourth stage of filter media (see section 3.1a). These filters must be checked regularly. Operating the unit with dirty filters will reduce the airflow and current draw, but will do no harm to the unit. The unit can be run indefinitely with dirty filters.

CAUTION

CAUTION: The unit must always be operated with all three filters and the top in place. Operating it with one or more filters missing, the top off, and/or inferior filters will cause amperage to increase and may cause the motor to overload. Permanent damage could result.

The three standard filters used are listed below (as installed in the unit from top to bottom):

- A. Polyester media pad pre-filter. Actual size is 23-3/8" x 23-3/8" x 1" thick. The white side faces up. This filter should be replaced when the airflow is reduced, it is visibly dirty or when it is contaminated by a previous job.
- B. 25 to 30% efficient (per ASHRAE 52.1-1992), MERV-7, pleated fabric filter. Actual size is 23-3/8" x 23-3/8" x 1-3/4". This filter should be changed when airflow is reduced or it is contaminated by a previous job.
- C. 99.97% DOP efficient HEPA filter. Actual size is 23-3/8" x 23-3/8" x 12-1/2. It contains at least 175 sq. ft. of media. This filter should be changed when airflow is reduced or it is contaminated by a previous job.

3.1A Activated Carbon/Potassium Permanganate Filters

Two optional gas phase filters are available from Therma-Stor: a disposable and a refillable. Each uses a blend of activated carbon and potassium permanganate. This blend removes the vast majority of contaminants encountered in most filtering applications. The activated carbon removes the heavier volatile organics while the potassium permanganate removes lower molecular weight contaminants. This is well suited to the smoke odors present after fire damage.

The life of the media blend depends upon both the hours used and the contamination level. Another advantage of the blended media versus activated carbon only is that part of the blend changes color as it loads up with contaminants. It starts out black, then turns pink, then brown, and finally white. It is best changed when it passes the brown stage and begins to turn white. It has lost most of its effectiveness at that point. When these filters are installed, the pad filter does not need to be installed above

them. This allows the operator to check the media color through the top grill of the unit without removing the top. These filters are the same size as the pleated fabric filter. They are installed above that pleated fabric filter. The pleated fabric filter catches carbon dust that comes off these filters before it reaches the HEPA filter.

The refillable carbon filter is metal-framed and can be refilled with carbon blend media purchased in 5-gallon buckets. The amount of carbon blend media loaded into the filter can be adjusted to the particular amount gas/odor removal required.

The disposable filter contains 7½ pounds of active media.


3.2 Checking Airflow

An inclined tube manometer is attached to the unit to determine if the filters need replacing. It measures negative static pressure between the blower inlet and the HEPA filter outlet.

To check airflow:

- Remove any inlet or outlet ducting, but leave the top and all filters in place. Make sure the unit is sitting level.
- Turn the unit on high speed for at least 15 minutes. Read the number values for the fluid levels in the upper and lower tubes. The fluid levels are slanted. Read the level at the center of both tubes.
- Subtract the lower tube number from the upper tube number. Match this difference to the chart on the manometer label to establish the percentage of clean air flow.

Calculation					
43	51	57	60	62	64
100%	90%	80%	70%	60%	50%
Percentage					



Airflow on high speed with all filters clean and no ducting is about 1400 CFM. The unit can be run with very dirty filters and virtually no flow without harming the unit. The operator's decision to change filters should be based on filter cost versus the unit's filtering effectiveness. If airflow is 700 CFM versus 1400 CFM, the unit will filter particles from a space at half the rate. The operator must judge if that is acceptable.

If the operator determines the filters should be changed due to low airflow, it is most economical to change them in the following order:

- Change the pad pre-filter (top) first. This is the least expensive filter. Recheck the airflow. If the airflow is acceptable, no other filters need to be changed.
- Change the pleated fabric filter (middle) second. It is the second least expensive filter. Recheck the airflow. If acceptable, the HEPA filter does not need changing.
- If the airflow is still too low, the HEPA filter must be changed.

4 Service

CAUTION

CAUTION: Servicing the Phoenix Guardian with its high voltage circuitry presents a health hazard that could result in death, serious bodily injury, and/or property damage. Only qualified service people should service this unit.

4.1 Warranty

A warranty certificate has been enclosed with this unit. Read it before any repair is initiated. If a warranty repair is required, call the factory first at 1-800-533-7533 for warranty claim authorization and technical assistance.

4.2 Blower Motor Replacement

Occasionally the blower may not start on low speed. If this occurs, start the unit on high speed, then switch it to low speed.

The centrifugal blower has a PSC motor and internal thermal overload protection. Follow the steps below to change the motor:

1. Unplug the power cord.
2. Remove the top and all air filters.
3. Remove the wire nut that connects the blower's white lead to the wire harness. Disconnect the motor's green ground wire from the unit. Remove the black and red wires from the switch.
4. Remove the four nuts that fasten the blower mounting flanges to the base of the unit.
5. Lift the blower out of the unit.
6. Loosen the set screw that holds the impeller hub to the motor shaft.
7. Lay the blower on its side, motor up.
8. Remove the 3 screws that fasten the motor support brackets to the blower housing.
9. Lift out the motor with support brackets.
10. Remove the two screws (one at each motor end) that hold the support brackets to the motor end mounting rings.
11. Remove the six screws that hold the support bracket halves together. Note which holes and slots they were located in.
12. Reassembling with the new motor is the above procedure reversed






Figure 13: Electrical Schematic

5 Service Parts

Item	Part No.	Qty.	Description
1	4023374	1	Air Filter, Polyester, 1" x 24" x 24"
2	4023375	1	Air Filter, Pleated, 2" x 24" x 24"
3	4024741	1	Air Filter, HEPA, 24" x 24" x 12" (99.97% DOP)
4	4024845	1	Axle
*	4024816	2	Axle Cap
*	4024817	2	Axle Cap Washer
*	1242497	2	Axle Washer
5	4023121	1	Blower (Lau DD10-8A)
6	4024813	1	Cord
*	4024811	1	Wire Harness
7	4024073	2	Foot
8	4024076	1	Duct Adapter, 12" Flex Duct, Inlet/Outlet
9	4024808	2	Duct Guide, Outlet Duct Collar
10	4024078	2	Duct Outlet Collar 12" X 5.75" For 10" Lay-Flat Duct (Not Shown)
11	4024079	1	Duct Outlet Collar 12" X 10.5" For 14" Lay-Flat Duct (Not Shown)
12	4024810	1	Handle
*	4024069	2	Handle Bracket
13	4021597	1	Hour Meter
14	4024867	1	Manometer Label
15	4024873	1	Manometer Tubing
16	4023114	1	Motor, 115V,.75Hp, 1625/1180RPM (Fasco P/N 7124-2020)
17	4023362	*	Nut, Plastic, 1/4-20 (Not Shown)
18	4024083	3	Snap Button
19	4024809	1	Suspension Foam Pad (Not Shown)
20	4024871	1	Switch, DPDT, On-Off-On
21	4024827	6	Thumb Screw, 1/4-20 X 1/2" Long
22	4024868	4	Thumb Screw, 1/4-20 X 1 1/2" Long
23	4024085	1	Top
24	4025070	2	Wheel, 10"
	4021591	2	Wheel, 10" (old) shown

Optional Parts

4023487	Air Filter, Disposable Carbon Blend 2" X 24" X 24"
4024764	Air Filter, Refillable Carbon Blend 2" X 24" X 24"
4024528	Carbon Blend, 5 Gal Pail
4024750	Duct, Flex, 12" X 25'
4023643	Duct, Flex, 18" X 25'
4024935	Duct, Lay Flat, 10" X 250'
4024936	Duct, Lay Flat, 14" X 250'



Specifications subject to change without notice.

Phoenix Guardian HEPA System Limited Warranty

Warrantor:

Therma-Stor LLC
PO Box 8680
Madison, WI 53708
Telephone: 1-800-533-7533

Who Is Covered: This warranty extends only to the original end-user of the Phoenix Guardian HEPA System, and may not be assigned or transferred.

First Year Warranty: Therma-Stor Products warrants that, for one (1) year the Phoenix Guardian HEPA System will operate free from any defects in materials and workmanship, or Therma-Stor Products will, at its option, repair or replace the defective part(s), free of any charge.

End-User Responsibilities: Warranty service must be performed by a Servicer authorized by Therma-Stor Products. If the end-user is unable to locate or obtain warranty service from an authorized Servicer, he should call Therma-Stor Products at the above number and ask for the Therma-Stor Products Service Department, which will then arrange for covered warranty service. Warranty service will be performed during normal working hours.

The end-user must present proof of purchase (lease) upon request, by use of the warranty card or other reasonable and reliable means. The end-user is responsible for normal care. This warranty does not cover any defect, malfunction, etc. resulting from misuse, abuse, lack of normal care, corrosion, freezing, tampering, modification, unauthorized or improper repair or installation, accident, acts of nature or any other cause beyond Therma-Stor Products' reasonable control.

Limitations and Exclusions: If any Phoenix Guardian HEPA System part is repaired or replaced, the new part shall be warranted for only the remainder of the original warranty period applicable thereto (but all warranty periods will be extended by the period of time, if any, that the Phoenix Guardian HEPA System is out of service while awaiting covered warranty service).

UPON THE EXPIRATION OF THE WRITTEN WARRANTY APPLICABLE TO THE PHOENIX GUARDIAN HEPA SYSTEM OR ANY PART THEREOF, ALL OTHER WARRANTIES IMPLIED BY LAW, INCLUDING MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE, SHALL ALSO EXPIRE. ALL WARRANTIES MADE BY THERMA-STOR PRODUCTS ARE SET FORTH HEREIN, AND NO CLAIM MAY BE MADE AGAINST THERMA-STOR PRODUCTS BASED ON ANY ORAL WARRANTY. IN NO EVENT SHALL THERMA-STOR PRODUCTS, IN CONNECTION WITH THE SALE, INSTALLATION, USE, REPAIR OR REPLACEMENT OF ANY GUARDIAN HEPA SYSTEM OR PART THEREOF BE LIABLE UNDER ANY LEGAL THEORY FOR ANY SPECIAL, INDIRECT OR CONSEQUENTIAL DAMAGES INCLUDING WITHOUT LIMITATION WATER DAMAGE (THE END-USER SHOULD TAKE PRECAUTIONS AGAINST SAME), LOST PROFITS, DELAY, OR LOSS OF USE OR DAMAGE TO ANY REAL OR PERSONAL PROPERTY.

Some states do not allow limitations on how long an implied warranty lasts, and some do not allow the exclusion or limitation of incidental or consequential damages, so one or both of these limitations may not apply to you.

Legal Rights: This warranty gives you specific legal rights, and you may also have other rights which vary from state to state.

TS-237

